



NQ9S

Single Station Smoke Detector

Characteristics


- New design on minified chamber makes so easy for maintenance.
- High luminous LED for light guiding design.
- Detector has passed strict E MC test, which greatly eliminates false alarms caused by interference from nearby sources.
- Simple test method: P ress test button to hear the alarm sound and confirm the unit is in normal condition.
- Easy installation: Install directly to proper location without any wiring.
- It is equipped with 9VDC battery, and optional 100~240 VAC power plug is available.
- Optional relay output : COM. NO. NC.
- Optional series connection wiring can co-activate up to 20 detectors.

Specifications

| | |
|---------------------|--|
| Model | NQ9S |
| Power | 9V battery |
| Sensitivity Setting | Comply to EN14604 |
| Indicator | Standby: flash every 45 seconds |
| | Alarm: flash and beep continuously |
| | Battery abnormal: beeps and flash intermittently |
| Sound | 90dB / M and above |
| Ambient Temperature | -10°C ~ +55°C |
| Material | Fire-proof plastic |
| Dimensions | 102mm(Dia.) x 48mm(H) |
| Weight | About 165g |
| Color | White |
| Optional Function | Type 1 : 9V battery |
| | Type 2 : includes signal transfer COM. NO. N.C. |
| | Type 3 : Type 2 + Type 4 |
| | Type 4 : build-in 110VAC or 220VAC plug |

Effective alert area

| Building Height | Area Covered |
|-----------------|--------------------|
| Under 4M | 150 M ² |
| 4 ~ 20M | 75 M ² |



EN14604



Distributor in Vietnam:

VIET BAO FIREFIGHTING AND PREVENTING EQUIPMENT COMPANY LIMITED.



140 Nguyen Van Thu St (Ground floor), DaKao ward, Dist.1, HCMC.

Tel: 84.28.39101156 – 39101157. Fax: 84.28.39101158

Email: vietbao@vietbaopccc.com.vn Website: http://vietbaopccc.com.vn